

BS APPROVALS BY COLLAR



H655

FIRE RESISTANCE

PIPE	PIPE DIAMETER	PIPE WALL THICKNESS	INTEGRITY	INSULATION
U-PVC, P-PVC and C-PVC	42 to 69 mm	2.6 to 5 mm	240	240
HDPE, MDPE. ABS	40 to 63 mm	3.3 to 3.7 mm	240	240
PP-R	56 to 63 mm	3.5 mm	240	240

H1005

PIPE	PIPE DIAMETER	PIPE WALL THICKNESS	INTEGRITY	INSULATION
U-PVC, P-PVC and C-PVC	56 to 110 mm	2.4 to 5.0 mm	240	240
HDPE, MDPE. ABS	50 to 110 mm	4.7 to 10.0 mm	240	180
PP-R	50 to 110 mm	8.0 to 15.0 mm	240	180
Rehau Raupiano	75 to 110 mm	1.9 to 2.7 mm	240	240
Valsir Triplus	75 to 110 mm	3.0 to 3.9 mm	240	240
Akatherm dBlue	75 to 110 mm	2.3 to 3.4 mm	240	240

H1505

PIPE	PIPE DIAMETER	PIPE WALL THICKNESS	INTEGRITY	INSULATION
U-PVC, P-PVC and C-PVC	110 to 160 mm	3.2 to 4.0 mm	240	240
HDPE, MDPE. ABS	125 to 160 mm	5.0 to 15.0 mm	240	120
PP-R	160 mm	23.0 mm	240	180
Rehau Raupiano	160 mm	4.2 mm	240	240
Valsir Triplus	160 mm	5.4 mm	240	180
Akatherm dBlue	160 mm	6.0 mm	240	120

BS 476: Part 20: 1987



Distributed by



T: 020 8699 6777 | F: 020 8699 6709
E: sales@selkentfastenings.com
www.selkentfastenings.com