

EN APPROVALS BY COLLAR



H655

FIRE RESISTANCE

PIPE	PIPE DIAMETER	PIPE WALL THICKNESS	INTEGRITY	INSULATION
PVC	40 to 65 mm	3.0 to 4.7 mm	180	240
PVC + COUPLING	40 to 65 mm	3.0 to 4.7 mm	180	240
PP	40 to 50 mm	1.8 mm	180	240
PP + COUPLING	40 to 50 mm	1.8 mm	180	240
PE-HD	25 to 63 mm	2.0 to 5.8 mm	180	240
PE-X	15 to 63 mm	2.6 to 8.6 mm	90	90

H1005 & H1105

PIPE	PIPE DIAMETER	PIPE WALL THICKNESS	INTEGRITY	INSULATION
PVC	50 to 100 mm	2.0 to 3.2 mm	180	180
PVC + COUPLING	50 to 100 mm	2.0 to 6.6 mm	180	180
PP	50 to 110 mm	1.8 to 2.7 mm	120	180
PP + COUPLING	110 mm	3.4 mm	180	240
PE-HD	50 to 110 mm	3.0 to 10.0 mm	120	120

H1505

PIPE	PIPE DIAMETER	PIPE WALL THICKNESS	INTEGRITY	INSULATION
PVC	100 to 150 mm	2.0 to 3.2 mm	120	120
PVC + COUPLING	100 to 150 mm	6.6 to 9.5 mm	120	180
PP	160 mm	3.9 to 4.9 mm	120	120
PP + COUPLING	110 mm	3.4 mm	180	240
PE-HD	110 to 160 mm	4.2 to 14.6 mm	120	120

EN 15 882-3: 2009



Distributed by



T: 020 8699 6777 | F: 020 8699 6709
 E: sales@selkentfastenings.com
 www.selkentfastenings.com