

BS APPROVALS BY PIPE



U-PVC, P-PVC and C-PVC pipes

FIRE RESISTANCE

COLLAR	PIPE DIAMETER	PIPE WALL THICKNESS	INTEGRITY	INSULATION
H65S	42 to 69 mm	2.6 to 5.0 mm	240	240
H100S	56 to 110 mm	2.4 to 5.0 mm	240	240
H150FWS	110 to 160 mm	3.2 to 4.0 mm	240	240

HDPE, MDPE and ABS pipes

COLLAR	PIPE DIAMETER	PIPE WALL THICKNESS	INTEGRITY	INSULATION
H65S	40 to 63 mm	3.3 to 3.7 mm	240	240
H100S	50 to 110 mm	4.7 to 10.0 mm	240	180
H150FWS	125 to 160 mm	5.0 to 15.0 mm	240	120

PP-R pipes

COLLAR	PIPE DIAMETER	PIPE WALL THICKNESS	INTEGRITY	INSULATION
H65S	56 to 63 mm	3.5 mm	240	240
H100S	50 to 110 mm	8.0 to 15.0 mm	240	180
H150FWS	160 mm	23.0 mm	240	180

Rehau Raupiano Plus pipes

COLLAR	PIPE DIAMETER	PIPE WALL THICKNESS	INTEGRITY	INSULATION
H100S	75 to 110 mm	1.9 to 2.7 mm	240	240
H150FWS	160 mm	4.2 mm	240	240

Valsir Triplus pipes

COLLAR	PIPE DIAMETER	PIPE WALL THICKNESS	INTEGRITY	INSULATION
H100S	75 to 110 mm	3.0 to 3.9 mm	240	240
H150FWS	160 mm	5.4 mm	240	180

Akatherm dBlue pipes

COLLAR	PIPE DIAMETER	PIPE WALL THICKNESS	INTEGRITY	INSULATION
H100S	75 to 110 mm	2.3 to 3.4 mm	240	240
H150FWS	160 mm	6.0 mm	240	120

BS 476: Part 20: 1987



Distributed by



T: 020 8699 6777 | F: 020 8699 6709
E: sales@selkentfastenings.com
www.selkentfastenings.com