

EN APPROVALS BY PIPE



PVC

FIRE RESISTANCE

COLLAR	PIPE DIAMETER	PIPE WALL THICKNESS	INTEGRITY	INSULATION
H65S	40 to 65 mm	3.0 to 4.7 mm	180	240
H100S & H110S	50 to 100 mm	2.0 to 3.2 mm	180	180
H150FWS	100 to 150 mm	2.0 to 3.2 mm	120	120

PVC + Coupling

COLLAR	PIPE DIAMETER	PIPE WALL THICKNESS	INTEGRITY	INSULATION
H65S	40 to 65 mm	3.0 to 4.7 mm	180	240
H100S & H110S	50 to 100 mm	2.0 to 6.6 mm	180	180
H150FWS	100to 150 mm	6.6 to 9.5 mm	120	180

PP

COLLAR	PIPE DIAMETER	PIPE WALL THICKNESS	INTEGRITY	INSULATION
H65S	40 to 50 mm	1.8 mm	180	240
H100S & H110S	50 to 110 mm	1.8 to 2.7 mm	120	180
H150FWS	160 mm	3.9 to 4.9 mm	120	120

PP + Coupling

COLLAR	PIPE DIAMETER	PIPE WALL THICKNESS	INTEGRITY	INSULATION
H65S	40 to 50 mm	1.8 mm	180	240
H100S & H110S	110 mm	3.4 mm	180	240
H150FWS	110 mm	3.4 mm	180	240

PE-HD

COLLAR	PIPE DIAMETER	PIPE WALL THICKNESS	INTEGRITY	INSULATION
H65S	25 to 63 mm	2.0 to 5.8 mm	180	240
H100S & H110S	50 to 110 mm	3.0 to 10.0 mm	120	120
H150FWS	100 to 160 mm	4.2 to 14.6 mm	120	120

PE-X

COLLAR	PIPE DIAMETER	PIPE WALL THICKNESS	INTEGRITY	INSULATION
H65S-RR	15 to 63 mm	2.6 to 8.6 mm	90	90

EN 15 882-3: 2009



Distributed by



T: 020 8699 6777 | F: 020 8699 6709
 E: sales@selkentfastenings.com
 www.selkentfastenings.com